

# バッテリー設備メンテナンス事業



英工電機株式会社  
EIKOH DENKI CO. LTD



蓄電池点検

蓄電池No.	測定電圧(V)	内阻値(Ω)	判定	蓄電池No.	測定電圧(V)	内阻値(Ω)	判定	蓄電池No.	測定電圧(V)	内阻値(Ω)	判定	蓄電池No.	測定電圧(V)	内阻値(Ω)	判定
1	2.274	0.400	OK	41	2.282	0.400	OK	81	2.273	0.397	OK	121	2.271	0.400	OK
2	2.274	0.400	OK	42	2.282	0.400	OK	82	2.273	0.397	OK	122	2.271	0.400	OK
3	2.274	0.400	OK	43	2.282	0.400	OK	83	2.273	0.397	OK	123	2.271	0.400	OK
4	2.274	0.400	OK	44	2.282	0.400	OK	84	2.273	0.397	OK	124	2.271	0.400	OK
5	2.274	0.400	OK	45	2.282	0.400	OK	85	2.273	0.397	OK	125	2.271	0.400	OK
6	2.274	0.400	OK	46	2.282	0.400	OK	86	2.273	0.397	OK	126	2.271	0.400	OK
7	2.274	0.400	OK	47	2.282	0.400	OK	87	2.273	0.397	OK	127	2.271	0.400	OK
8	2.274	0.400	OK	48	2.282	0.400	OK	88	2.273	0.397	OK	128	2.271	0.400	OK
9	2.274	0.400	OK	49	2.282	0.400	OK	89	2.273	0.397	OK	129	2.271	0.400	OK
10	2.274	0.400	OK	50	2.282	0.400	OK	90	2.273	0.397	OK	130	2.271	0.400	OK
11	2.274	0.400	OK	51	2.282	0.400	OK	91	2.273	0.397	OK	131	2.271	0.400	OK
12	2.274	0.400	OK	52	2.282	0.400	OK	92	2.273	0.397	OK	132	2.271	0.400	OK
13	2.274	0.400	OK	53	2.282	0.400	OK	93	2.273	0.397	OK	133	2.271	0.400	OK
14	2.274	0.400	OK	54	2.282	0.400	OK	94	2.273	0.397	OK	134	2.271	0.400	OK
15	2.274	0.400	OK	55	2.282	0.400	OK	95	2.273	0.397	OK	135	2.271	0.400	OK
16	2.274	0.400	OK	56	2.282	0.400	OK	96	2.273	0.397	OK	136	2.271	0.400	OK
17	2.274	0.400	OK	57	2.282	0.400	OK	97	2.273	0.397	OK	137	2.271	0.400	OK
18	2.274	0.400	OK	58	2.282	0.400	OK	98	2.273	0.397	OK	138	2.271	0.400	OK
19	2.274	0.400	OK	59	2.282	0.400	OK	99	2.273	0.397	OK	139	2.271	0.400	OK
20	2.274	0.400	OK	60	2.282	0.400	OK	100	2.273	0.397	OK	140	2.271	0.400	OK
21	2.274	0.400	OK	61	2.282	0.400	OK	101	2.273	0.397	OK	141	2.271	0.400	OK
22	2.274	0.400	OK	62	2.282	0.400	OK	102	2.273	0.397	OK	142	2.271	0.400	OK
23	2.274	0.400	OK	63	2.282	0.400	OK	103	2.273	0.397	OK	143	2.271	0.400	OK
24	2.274	0.400	OK	64	2.282	0.400	OK	104	2.273	0.397	OK	144	2.271	0.400	OK
25	2.274	0.400	OK	65	2.282	0.400	OK	105	2.273	0.397	OK	145	2.271	0.400	OK
26	2.274	0.400	OK	66	2.282	0.400	OK	106	2.273	0.397	OK	146	2.271	0.400	OK
27	2.274	0.400	OK	67	2.282	0.400	OK	107	2.273	0.397	OK	147	2.271	0.400	OK
28	2.274	0.400	OK	68	2.282	0.400	OK	108	2.273	0.397	OK	148	2.271	0.400	OK
29	2.274	0.400	OK	69	2.282	0.400	OK	109	2.273	0.397	OK	149	2.271	0.400	OK
30	2.274	0.400	OK	70	2.282	0.400	OK	110	2.273	0.397	OK	150	2.271	0.400	OK
31	2.274	0.400	OK	71	2.282	0.400	OK	111	2.273	0.397	OK	151	2.271	0.400	OK
32	2.274	0.400	OK	72	2.282	0.400	OK	112	2.273	0.397	OK	152	2.271	0.400	OK
33	2.274	0.400	OK	73	2.282	0.400	OK	113	2.273	0.397	OK	153	2.271	0.400	OK
34	2.274	0.400	OK	74	2.282	0.400	OK	114	2.273	0.397	OK	154	2.271	0.400	OK
35	2.274	0.400	OK	75	2.282	0.400	OK	115	2.273	0.397	OK	155	2.271	0.400	OK
36	2.274	0.400	OK	76	2.282	0.400	OK	116	2.273	0.397	OK	156	2.271	0.400	OK
37	2.274	0.400	OK	77	2.282	0.400	OK	117	2.273	0.397	OK	157	2.271	0.400	OK
38	2.274	0.400	OK	78	2.282	0.400	OK	118	2.273	0.397	OK	158	2.271	0.400	OK
39	2.274	0.400	OK	79	2.282	0.400	OK	119	2.273	0.397	OK	159	2.271	0.400	OK
40	2.274	0.400	OK	80	2.282	0.400	OK	120	2.273	0.397	OK	160	2.271	0.400	OK

